


**NOTES:**

1. CONCRETE SHALL BE 3000 PSI MIN. (CL 3000), 3-1/2" SLUMP (MAX.), MEDIUM BROOM FINISH PARALLEL TO DRIVEWAY CENTERLINE MEETING WSDOT STANDARD SPECIFICATION 6-02.3(2)B.
2. COMMERCIAL DRIVEWAYS REQUIRE 8" CONCRETE WITH REINFORCING STEEL (6x6 - W2.9xW2.9 WWF, MIN.), 1 1/2" COVER FROM BOTTOM OF SLAB. RESIDENTIAL DRIVEWAYS REQUIRE 6" CONCRETE.
3. COMPACT SUBGRADE AND AGGREGATE TO 95% OF MAXIMUM DRY DENSITY (3" MIN. DEPTH).
4. DRIVEWAYS EXCEEDING 15' IN TOTAL WIDTH SHALL HAVE ADDITIONAL LONGITUDINAL JOINTS AS DIRECTED. JOINT SPACING SHALL NOT EXCEED 15'. SEE CONCRETE JOINTS DETAIL TR-5.01.
5. EXISTING CURB SHALL BE REMOVED TO EXISTING JOINT OR SAWCUT SUCH THAT 3' MIN. OF NEW CURB IS CONSTRUCTED ADJACENT TO NEW DRIVEWAY.
6. SEE PAVEMENT RESTORATION AT CURBS DETAIL TR-5.00 WHEN CUTTING EXISTING CURB.
7. ALL EXISTING EDGES SHALL BE SAWCUT.
8. STRUCTURAL SECTION OF DRIVEWAY TO BE EXTENDED THROUGH SIDEWALK AREA.
9. DRIVEWAYS SHALL BE PER THE WIDTH INDICATED ON THE PLANS.
10. TRANSITION CURB FROM FULL 6" EXPOSURE TO 0" OVER THE FIRST 6' FROM CORNER.
11. MAY ONLY BE USED FOR COMMERCIAL PROPERTIES EXCEEDING 1000 ADT AND MUST BE APPROVED BY CITY ENGINEER.
12. MAXIMUM 2% CROSS SLOPE ACROSS PEDESTRIAN CROSSING.

N.T.S.

**MAJOR COMMERCIAL DRIVEWAY - DETACHED SIDEWALK**

PLAN #



CITY OF BATTLE GROUND  
APPROVED

*Rb*  
6/3/08

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	1/31/08	JMH	MCH
2	6/3/08	JMH	MCH

TR-3.08