



NOTES:

1. CONCRETE SHALL BE 3000 PSI MIN. MEETING WSDOT STANDARD SPECIFICATIONS 6-02.3(2)B.
2. COMPACT SUBGRADE AND AGGREGATE TO 95% OF MAXIMUM DRY DENSITY (3" MIN.).
3. FINISH SHALL BE MEDIUM BROOM PERPENDICULAR TO PEDESTRIAN TRAFFIC UNLESS OTHERWISE DIRECTED.
4. 2" SMOOTH FINISH BORDER AROUND EACH SIDEWALK PANEL OR MATCH EXISTING BORDER.
5. SEE CONCRETE JOINTS DETAIL TR-5.01 FOR SURFACE, CONTRACTION, AND EXPANSION JOINTS.
6. ALL EXISTING EDGES SHALL BE SAWCUT.
7. CROSS SLOPE OF PLANTER STRIP SHALL BE 2% (TYP.).

N.T.S.

TYPICAL SIDEWALK

PLAN #



CITY OF BATTLE GROUND
APPROVED

Rl
CITY ENGINEER
6/3/08
DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	6/3/08	JMH	MCH

TR-4.00