



NOTES:

1. INSTALL URBAN ACCESSORIES KIVU TREE GRATE OR APPROVED EQUAL AT ALL TREE WELLS.
2. CITY ENGINEER MUST APPROVE EQUALS.
3. GRATES MUST BE CAST IN A MINIMUM OF 2 PIECES.
4. NO OPENINGS GREATER THAN $\frac{3}{8}$ ".
5. CAST IRON PER ASTM A-48 CLASS 35B OR BETTER.
6. MINIMUM THICKNESS $\frac{3}{4}$ ".
7. BREAKOUT RINGS AT 22" AND 33".
8. FINISH: NATURAL CAST IRON.
9. INSTALL PER MANUFACTURER'S SPECIFICATIONS. TOP OF GRATE SHALL BE FLUSH WITH SIDEWALK.
10. GRATES WILL VARY BETWEEN 42" MINIMUM AND 72" MAXIMUM.

N.T.S.

TREE GRATE

PLAN #



CITY OF BATTLE GROUND
APPROVED

Rt W
6/6/08
CITY ENGINEER DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	3/18/06	CMS	SMK
2	6/6/08	JMH	MCH

TR-4.02