


**CONSTRUCTION NOTES:**

1. FIRE HYDRANT INSTALLATIONS SHALL BE APPROVED BY THE CITY INSPECTOR PRIOR TO BACKFILLING.
2. IN GENERAL FIRE HYDRANT LOCATIONS SHALL BE AS SHOWN ON THE PLANS BUT SHALL CONFORM TO THIS DETAIL. FIRE HYDRANTS SHALL NOT BE SET UNTIL LOCATION AND DEPTH ARE APPROVED BY THE CITY.
3. NO DOMESTIC OR FIRE PROTECTION SERVICES SHALL BE TAPPED OFF OF THE FIRE HYDRANT PIPING.
4. A 4'x4'x4" CONCRETE PAD SHALL BE CENTERED AROUND THE FIRE HYDRANT.
5. CONCRETE PAD SHALL BE PLACED FLUSH IN ELEVATION AND ADJOINED W/BACK OF CURB (IF SIDEWALK IS DETACHED) OR BACK OF SIDEWALK (IF SIDEWALK IS ATTACHED). EXPANSION JOINT MATERIAL SHALL BE PLACED BETWEEN THE CONCRETE PAD AND CURB/SIDEWALK AND BETWEEN CONCRETE AND FIRE HYDRANT.
6. CONCRETE PAD SHALL BE FINISHED TO SIDEWALK STANDARDS.
7. ALL JOINTS SHALL BE RESTRAINED UTILIZING MECHANICAL RESTRAINT SYSTEMS. CONCRETE THRUST BLOCKS SHALL NOT BE ALLOWED.
8. FIRE HYDRANTS SHALL BE FACTORY PAINTED WITH SAFETY YELLOW HIGH GLOSS EQUIPMENT ENAMEL (TOUCH UP IF NECESSARY AFTER INSTALLATION).
9. FIRE HYDRANT MAINS SHALL BE 8" MIN., A 6" MAIN CAN BE USED FOR A DEAD-END RUN OF LESS THAN 50' TO A HYDRANT SUBJECT TO ADEQUATE FIRE FLOW.
10. PROVIDE A BLUE TYPE 2 RPM @ CENTERLINE ON HYDRANT SIDE OF STREET.

**FIRE HYDRANT ASSEMBLY**

PLAN #



CITY OF BATTLE GROUND  
 APPROVED

*[Signature]*  
 CITY ENGINEER

9/24/07  
 DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	4/16/07	JMH	MCH
2	9/24/07	MCH	MCH

WA-2.3