


NOTES:

1. WATER METERS ARE NOT ALLOWED IN THE DRIVEWAY WING EXTENSION AREAS.
2. ALL DEDUCT METERS SHALL BE PER APPROVED PLAN.
3. DEDUCT METERS SHALL BE PLACED IN A STANDARD METER BOX WITH READER LID ACCORDING TO METER SIZE (SEE WA-2.0 & WA-2.1).
4. DEDUCT METERS SHALL BE CONSTRUCTED PER THE DOMESTIC METER DETAIL OF THE SAME METER SIZE (SEE WA-2.0, WA-2.1 & WA-2.2).
5. DEDUCT METERS SHALL BE PURCHASED FROM THE CITY OF BATTLE GROUND.
6. DEDUCT METERS ARE SUPPLIED AND INSTALLED (UP TO 1") BY THE CITY OF BATTLE GROUND. LARGER METERS ARE TO BE INSTALLED BY CONTRACTOR.
7. DEDUCT METERS SHALL BE OWNED AND MAINTAINED BY THE CUSTOMER, INCLUDING ANY BATTERY REPLACEMENT.
8. EXCEPTIONS TO THESE REQUIREMENTS SHALL BE SUBMITTED IN WRITING WITH A PLAN FOR REVIEW BY THE CITY OF BATTLE GROUND ENGINEERING DIVISION.
9. DIRECT ALL DESIGN QUESTIONS TO THE CITY ENGINEERING DIVISION AT (360) 342-5070.
10. PLUMBING PERMIT REQUIRED.

N.T.S.

DEDUCT METER

STANDARD  
DETAIL



CITY OF BATTLE GROUND  
APPROVED

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	5/26/11	RMJ	RMJ
2	7/20/15	JMH	ME

*Mark Hervey* 7/23/15  
CITY ENGINEER                      DATE

WA-6.3