

GENERAL NOTES:

1. MATERIALS AND WORKMANSHIP FOR DRAINAGE WORK SHALL CONFORM TO THE LATEST EDITION OF THE WSDOT/APWA "STANDARD SPECIFICATIONS FOR ROAD, BRIDGE & MUNICIPAL CONSTRUCTION".
2. MATERIALS AND WORKMANSHIP FOR STORM SEWER WORK SHALL CONFORM TO THE LATEST EDITION OF THE "CITY OF BATTLE GROUND STANDARD DETAILS & CONSTRUCTION REQUIREMENTS."
3. THE CONTRACTOR IS TO VERIFY ALL INVERT AND TOP ELEVATIONS OF EXISTING STORM SEWERS, AND REPORT ANY DISCREPANCIES IMMEDIATELY TO THE ENGINEER.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DETERMINING THE LOCATION OF ALL UNDERGROUND UTILITIES PRIOR TO THE START OF CONSTRUCTION AND TO NOTIFY THE ENGINEER OF ANY POTENTIAL CONFLICTS. THE CONTRACTOR SHALL POTHOLE OVER ALL EXISTING UTILITIES PRIOR TO CONSTRUCTION TO DETERMINE THEIR EXACT LOCATION. CALL (360) 696-4848, (UTILITY COORDINATING COUNCIL), FOR LOCATION OF EXISTING UTILITIES, A MINIMUM OF 2 WORKING DAYS PRIOR TO START OF CONSTRUCTION.
5. IT SHALL BE THE RESPONSIBILITY OF THE DEVELOPER AND/OR CONTRACTOR TO PROCURE ALL APPLICABLE PERMITS, LICENSES AND CERTIFICATES RELATIVE TO THE TRADES TO COMPLETE THE PROJECT AND FOR THE USE OF SUCH WORK WHEN COMPLETED. COMPLIANCE SHALL BE AT ALL LEVELS, FEDERAL, STATE AND CITY, RELATING TO THE PERFORMANCE OF THIS WORK.
6. THE CONTRACTOR SHALL OBTAIN ALL OFFSITE CONSTRUCTION EASEMENTS PRIOR TO THE START OF CONSTRUCTION. THE CONTRACTOR SHALL VERIFY THAT ALL OFFSITE UTILITIES EASEMENTS HAVE BEEN OBTAINED BY THE OWNER PRIOR TO THE COMMENCEMENT OF ANY OFFSITE CONSTRUCTION.
7. ALL CATCH BASINS AND CURB INLETS SHALL BE STENCILED AS FOLLOWS:
"DUMP NO WASTE-DRAINS TO STREAM". (SEE STD. DETAIL TR-8.09)
8. SIGNS SHALL BE INSTALLED ALONG WATER QUALITY BIOFILTRATION SYSTEMS THAT READS:
"WATER QUALITY FILTER-PLEASE LEAVE VEGETATED". (SEE STD. DETAIL TR-7.13)
9. PIPES OVER 15" DIA. SHALL HAVE A TRASH SCREEN AT END OF PIPE, EXCEPT WHERE PIPE IS LOCATED WITHIN A FENCED STORM FACILITY. (SEE STD. DETAIL ST-6.6)
10. LOCKING LID MUST BE USED ON MANHOLES LOCATED IN NON-HARDSCAPE AREAS EXCEPT WHERE MANHOLE IS LOCATED WITHIN FENCED STORM FACILITY.
11. MATERIAL CERTIFICATION FOR ALL STORM MANHOLES, CATCH BASINS, AND CURB INLETS SHALL BE PROVIDED TO THE CITY INSPECTOR.
12. ALL ROOF AND LOWPOINT DRAINS TO BE DIRECTED TO APPROVED DRAINAGE PER PLANS.


TESTING:

1. ALL MAIN LINE RUNS, REGARDLESS OF SIZE, AND LATERALS OVER 50 FEET IN LENGTH SHALL BE TELEVISION INSPECTED. TOLERANCES FOR BELLYS SHALL BE NO MORE THAN 1/2" IN 8-INCH PIPE, 3/4" IN 10-INCH PIPE, AND 1" IN PIPES 12-INCHES OR GREATER. VARIATIONS IN EXCESS OF THESE TOLERANCES MUST BE REPAIRED AT THE CONTRACTOR'S EXPENSE TO THE SATISFACTION OF THE CITY.
2. EXFILTRATION TEST WSDOT SPECIFICATION 7-04.3(1)B FOR DETAINAGE OR AS REQUIRED BY CITY ENGINEER.

N.T.S.

STORMWATER GENERAL NOTES & TESTING

STANDARD
DETAIL



CITY OF BATTLE GROUND
APPROVED

Scott P. Sawyer 7-21-09
CITY ENGINEER DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	8/12/98	BSG	GGH
2	8/30/05	MDB	MCH
3	7/22/09	RMJ	RMJ

ST-1.0