

CONSTRUCTION NOTES:

1. IN OVER EXCAVATED AREAS PROVIDE SUPPORT FOR THE PIPE AS FOLLOWS: PLACE 3/4" MINUS CRUSHED ROCK OVER UNDISTURBED GROUND IN 6" LAYERS AND COMPACT.
2. BACKFILL MATERIAL BELOW & TO SIDE OF STRUCTURE SHALL BE ASTM D2321 CLASS I OR II CRUSHED STONE OR GRAVEL, PLACED UNIFORMLY. BACKFILL TO MEET WSDOT 7-05 & AASHTO T-99 95% COMPACTION.
3. ALL DIMENSIONS SUBJECT TO ALLOWABLE SPECIFICATION TOLERANCES.
4. ANY PROTRUDING ENDS OF PIPES SHALL BE TRIMMED FLUSH WITH THE INSIDE WALLS AND GROUTED TO THE SATISFACTION OF ENGINEER.
5. LIFT HOLES MUST BE GROUTED.


STRUCTURE NOTES:

1. MANHOLE TO BE CONSTRUCTED IN ACCORDANCE WITH ASTM C478 & C890 UNLESS SHOWN ON PLANS OR NOTED IN WSDOT STANDARD SPECIFICATIONS.
2. ALL PRECAST MANHOLE SECTIONS AND CONES SHALL CONFORM TO ASTM C-478 WITH CAST IN STEPS.
3. BASE CONCRETE SHALL BE 3000 P.S.I., 2-4 IN. SLUMP. FLOW LINES AND INSIDE SURFACES SHALL BE TROWELED SMOOTH & UNIFORM AT TIME OF POUR.
4. CAST-IN-PLACE, MONOLITHIC MANHOLE MAY BE SUBSTITUTED WITH SPECIFIC APPROVAL OF THE CITY ENGINEER.
5. JOINTS SHALL BE CONSTRUCTED SO AS TO BE WATERTIGHT. KENT-SEAL NO. 2 OR APPROVED EQUAL SHALL BE USED ON TONGUE & GROOVE SECTIONS, AND ON RISER RINGS PREMOLDED "O-RING" MAY BE SUBSTITUTED ON BELL & SPIGOT SECTIONS. ALL JOINTS SHALL BE GROUTED WITH PORTLAND CEMENT CONCRETE GROUT & STRUCK EVEN WITH THE WALL.
6. MANHOLES UNDER 6'-0" IN DEPTH FROM RIM TO BOTTOM SHALL HAVE A TOP SLAB IN LIEU OF CONE, SEE STD. DETAIL ST-2.2.
7. WHIRLY GIG © MANHOLE RISER COLLAR SYSTEM MAY BE USED IN PLACE OF RISER RING.
8. ALL REINFORCED STEEL SHALL HAVE 1 1/2" CLEAR COVER UNLESS OTHERWISE NOTED, AND SHALL BE GRADE 60 (ASTM A615).
9. STEEL REINFORCED OR POLYPROPYLENE FIBER REINFORCED UNITS ARE ALLOWABLE.

N.T.S.

MANHOLE

STANDARD
DETAIL



CITY OF BATTLE GROUND
APPROVED

Scott P. Sawyer 7-21-09
CITY ENGINEER DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	8/12/98	BSG	GGH
2	7/22/09	RMJ	RMJ

ST-2.0