



**NOTES:**

1. THE INLET SEDIMENT CONTROL DEVICE SHALL BE OF HIGH FLOW DESIGN (200 GAL/MIN/SQ FT), AS PER THE MANUFACTURER'S SPECS.
2. SUBSTITUTION OF A SHEET OF FILTER FABRIC PLACED OVER THE OPENING OF THE INLET IS NOT APPROVED.
3. THE FILTER SHALL BE REPLACED OR CLEANED WHEN THE INSERT BECOMES HALF FULL.
4. FOR SEDIMENT DAM REFER TO STANDARD DETAIL EC-4.02.
5. REFER TO BMP C220 IN VOLUME II OF THE WESTERN WASHINGTON MANUAL FOR MORE INFORMATION.

N.T.S.

**INLET PROTECTION (CATCH BASIN INSERT)**

STANDARD  
DETAIL



CITY OF BATTLE GROUND  
APPROVED

*Mark Heneg*

06/11/2018

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	9/15/10	RMJ	RMJ
2	3/07/17	CAS	KDU

EC-4.01