



**NOTES:**

1. THE CULVERT ENDS SHALL BE BEVELED TO MATCH THE EMBANKMENT OR DITCH SLOPE, WITHOUT EXCEEDING THE LIMITS SHOWN ON THE PLAN. SLOPE FOR BEVELED END SECTION SHALL MATCH BANK SIDE SLOPE UP TO A MAX. OF 3:1.
2. THE END OF CORRUGATED POLYETHYLENE SHALL BE ANCHORED. SEE STD. DETAIL ST-7.03.
3. FOR PIPES 15" OR LARGER, TRASH SCREEN REQUIRED. SEE STD. DETAIL ST-6.06.

N.T.S.

BEVELED END SECTION

STANDARD  
DETAIL



CITY OF BATTLE GROUND  
APPROVED

*Mark Heneg*

06/11/2018

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	7/22/09	RMJ	RMJ
2	3/31/17	CAS	KDU

ST-6.05