


NOTES:

1. SIDEWALK SLOPE TO BE 2% MAX. RADIALLY AROUND CORNER SECTION.
2. APPLY HEAVY BROOM FINISH ON ALL SLOPES GREATER THAN 2%.
3. PRECAST TRUNCATED DOMES REQUIRED ON ALL CURB RAMPS, PER DETAIL TR-4.04.
4. RAMPS SHALL HAVE A BRUSHED TEXTURE SURFACE APPLIED TO THE STILL FRESH CONCRETE.
5. THIS TYPE OF RAMP IS ONLY TO BE USED IN EXISTING ROAD LOCATIONS WHERE THE TYPE 1A CURB RAMP CAN NOT BE USED AND WHEN APPROVED BY THE CITY ENGINEER.

N.T.S.

TYPE 1B CURB RAMP

PLAN #

CITY OF BATTLE GROUND
APPROVED

6/6/08

CITY ENGINEER DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	8/12/98	BSG	GGH
2	8/30/05	ALL	MCH
3	6/6/08	JMH	MCH

TR-4.06